



DELHI JAL BOARD (GOVT. OF N.C.T. DELHI)
 QUALITY CONTROL LABORATORY,
 TRANS YAMUNA REGION TAHIRPUR DELHI-110093



NO: DJB/QCL TYR/PD/04/2304/02

NO: DJB/ACWA(TYR)/2023.....

DATE:- 29-04-2023

Analysis report of DJB supply water samples collected from (1) Inlet (2) Outlet. M/S Salwan Public School, Kondli Gharouli Complex, Mayur Vihar, Phase-III, Delhi- 96, for drinking purpose. Ref. No-SPS/MV/MCD/23-24/1717, dt 25-04-2023

Date of collection:- 27-04-2023

Challan No:- 37

dated:- 25-04-2023

S. No.	PARTICULARS	BIS:10500-2012 LIMITS		UNITS	RESULT	
		Desirable	Permissible		(1)	(2)
A.	Physical Examination					
1.	Colour	-	Clear	Clear
2.	Odour	-	Chlor.	Chlor.
3.	Turbidity	1.0	5.0	NTU	0.58	0.79
4.	pH Value	6.5-8.5	--	-	7.4	7.5
5.	Electrical Conductivity	--	--	µs/cm	272	276
6.	Total Dissolved Solids	500	2000	mg/l	177	179
B.	Chemical Examination					
7.	p ^h Alkalinity	45	NO RELAXATION	mg/l	NIL	NIL
8.	Total Alkalinity	200	600	mg/l	78	78
9.	Total Hardness	200	600	mg/l	96	92
10.	Calcium Hardness	mg/l	64	62
11.	Magnesium Hardness	mg/l	32	30
12.	Calcium as (Ca)	75	200	mg/l	25.6	24.8
13.	Magnesium as (Mg)	30	100	mg/l	7.68	7.20
14.	Ammonical Nitrogen	0.5	NO RELAXATION	mg/l	N.D	N.D
15.	Nitrite	mg/l	N.D	N.D
	Nitrate	45	NO RELAXATION	mg/l	1.68	2.09
17.	Sulphate	200	400	mg/l	36.70	38.26
18.	Chloride	250	1000	mg/l	22	22
19.	Fluoride	1.0	1.5	mg/l	0.14	0.19
20.	Total Iron	1.0	NO RELAXATION	mg/l	0.10	0.08
21.	Cyanide	0.05	NO RELAXATION	mg/l	N.D.	N.D.
22.	Residual Chlorine	0.2	1.0	mg/l	0.71	0.33
C.	Bacteriological Examination					
23.	Coliform count	Absent	NO RELAXATION	MPN/100ml	0	0

This Report Pertains To The Particular Sample Only

REMARKS:- On the basis of above tested parameters, both water samples conforms BIS: 10500-2012 and can be considered fit for drinking purpose.

[Signature]
A/CHEMIST

[Signature]
CHEMIST

[Signature]
BACT.

[Signature]
ACWA (TYR)
Asst. Chief Water Analyst
DJB, Govt. of N.C.T. of Delhi
Quality Control Zonal Laboratory (Tyr.)
Tahir Pur Dilansa Garden, Delhi-93

Salwan Public School
Kondli Gharouli Complex
Mayur Vihar Phase-III,
Delhi-110096

Director
Salwan Public School
Kondli Gharouli Complex
Mayur Vihar Phase-III,
Delhi-110096

Municipal Corporation of Delhi
Public Health Department
 Shahdara (South) Zone
 419, First Floor, Udyog Sadan,
 Patparganj Industrial Area, Delhi-11092

No. DHO/Shah.(S)/2022/D-510

Dated:- 16/9/2022

School Health Certificate

1. Name of School	: Salwan Public School
2. Location of the School	: Kondli Gharoli Complex, Mayur Vihar, Phase-III, Delhi-96
3. Timing of School	: 8 A.M. to 2:30 P.M
4. No. of Rooms	: 74
5. No. of Staff	: 64 Teacher, 13 Ministerial Staff
6. No. of Students	: 1656 (Boys-947, Girls-709)
7. No. of Desk & Chair	: Provided
8. No. of Doors In each room	: Exist in each room
9. No. of Windows in each room	: Exist in each room
10. No. of Toilets	: 29
11. No. of Urinals	: 38
12. Building Structure	: Pucca
13. Drinking Water	: Provided
14. Electricity	: Provided

At the time of inspection, school is found running under sanitary and hygiene conditions. This certificate is subject to provision of Fire Safety Certificate and its has no bearing on unauthorized construction of the premises if any and on any dispute regarding title of land.

This certificate/NOC is valid for (01) one year only.

The Principal,
 Salwan Public School
 Kondli Gharoli Complex,
 Mayur Vihar, Phase-III, Delhi-96

Deputy Health Officer
 Shahdara (South) Zone

DEPUTY HEALTH OFFICER
 MUNICIPAL CORPORATION OF DELHI
 SHAHDARA (SOUTH) ZONE


 Principal
 Salwan Public School
 Kondli Gharoli Complex
 Mayur Vihar Phase-III,
 Delhi-110096


 Director
 Salwan Public School
 Kondli Gharoli Complex
 Mayur Vihar Phase-III,
 Delhi-110096

